

SRI BAALAMURUGAN BOREWELLS

4, gangamma Compound, Opp. Canara Bank Bus Stop, Bellary Main Road, Helibal Bangalore - 24.
Mob : 9845020536, 9901920004

WORK REPORT

Prakrushi layout			No.	
			Date :	
S.No.	Particulars	Rft :	Water Yield	Remarks
1.	Size of The Borewell	160mm		
2.	Total Deapth of The Borewell	984'		
3.	MS Casing Erected	131'		
4.	1st Water Source at the Deapth	287'		
5.	2nd Water Source at the Deapth	516'		
6.	3rd Water Source at the Deapth	730'		
7.	4th Water Source at the Deapth	928'		
8.	If any Silt, Boulders at the Deapth	—		
9.	Nature of Water	Subsag Water		
10.	Moter Pump to be Used	15x125 stage		
11.	Any other Remarks	—		
12.	Total Yield of the Borewell	2'-0"		

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells

GROUND WATER SURVEY REPORT

OPEN WELL/ BOREWELL
DATA OF SURVEY

a) Name of the Party

AEE, Byataramyana Para

b) Location of the Site

Sub Division - B3MP Ward No-5

c) Area of the land

: Praksutti Nagara.

Annapoorneshwari Temple

INVESTIGATION REPORT

Back Side

1) GEOLOGY OF THE AREA

:

2) Recommended Site for drilling

:

3) Total depth to be drilled

: 900' to 1200'

4) Approx. casing pipe required

: 80.0 to 140'

5) No. of water bearing Zones

: 1

6) No. of favourable spots marked

: 1

7) Qty. of water expected

: 2" to 2 1/2"

8) Method of survey carried out

:


Geo

9) Remarks

:

BOREWELL SITE PLAN

Borewell site to be drilled



P.T.O. : Terms & Conditions

HYDROGEOLOGIST

(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

W.No 5

ಪ್ರತ್ಯೇಕ ನಗರ ಉಪವ್ಯಾಪ್ತ ವ್ಯವಸ್ಥಾಪನಾ ಇಲಾಖೆ



dy
A-05

W.No. 6

శ్రీశ్రీ నగర ఉపశాసనాధికారి కార్యాలయము



శ్రీ
AE-05